

ADDENDUM #7

This Addendum hereby forms part of the RFP. The purpose of this Addendum is to provide responses to questions received.

Question 1: Is the kitchen exhaust hood, KEF-1 and the makeup air unit MUA-1 included?

Answer 1: KH-1, KEF-1 and MUA-1 to be priced. Do not order equipment until finalized kitchen layout is approved and mechanical engineer reviews design.

Question 2: Please confirm that none of the kitchen equipment shown between Gridlines A3 and B6 minus are excluded from the tendered price. R2 same comment as above but it is a 2x12 so room to put the batt in but cross venting issue remains without purlins installed. Please confirm.

Answer 2: Please price for rough-in's and full coordination with specialist kitchen subtrade.

Question 3: There is no spec for any grills or diffusers:

- a. BT-1 doesn't have enough info to receive a proper quote – please provide more information
- b. LV-3 doesn't have enough info to receive a proper quote – please provide more information
- c. LV-4 is discontinued – is there an alternate product
- d. LV-5 is discontinued – is there an alternate product

Answer 3: Grille/diffuser/louver schedule provided in BP drawings on M-4.01 that were distributed. Schedule below included below.

GRILLE / DIFFUSER / LOUVER SCHEDULE					
TAG	MAKE	MODEL	FINISH	MOUNTING	NOTES
SD-1	EH PRICE	RPD	WHITE	DUCT	-
SG-1	EH PRICE	520L	WHITE	DUCT/WALL	1
SG-2	EH PRICE	LFG15A	WHITE	FLOOR	1
SG-3	EH PRICE	ND 12"Ø	WHITE	DUCT	1
RG-1	EH PRICE	80	WHITE	WALL	-
EG-1	EH PRICE	80	WHITE	CEILING	-
L-1	EH PRICE	DE639	WHITE	WALL	2

NOTES:
 1. INTEGRAL BALANCING DAMPER
 2. BIRD SCREEN

BT-1 and LV-3 to be standard residential equipment. American Standard – Aqualyn drop in sink for sink basin.

City of Langford – RFP for a General Construction Contractor for the Jordie Lunn Clubhouse

For any questions, please contact:

Yari Nielsen

Director of Parks, Recreation and Facilities

ynielsen@langford.ca